



PRODUCT CERTIFICATE

CERTIFICATE NO.: CQC2019010305206644

NAME AND ADDRESS OF THE APPLICANT

J&A Apply Control Technology (Suzhou) CO., Ltd.
Block C, #03-04/02, No. 5 Xing Han Street Suzhou

NAME AND ADDRESS OF THE MANUFACTURER

MAFELEC
471 ROUTE DE LA CUISINIERE, CHIMILIN-FRANCE

NAME AND ADDRESS OF THE FACTORY

MAFELEC (V056397)
471 ROUTE DE LA CUISINIERE, CHIMILIN-FRANCE

PRODUCT NAME, MODEL AND SPECIFICATION

Push Button Switch

83577, 83578; Ui: 500V; Uimp: 6kV; Ith: 10A; AC-15; Ue/Ie: AC230V/8A; Aperture: Φ 22mm;
Levels of Protection: IP20.

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T 14048.5-2017

TYPE OF CERTIFICATION SCHEMES

Type Testing of Product + Follow up Factory Inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC11-462142-2019 .

Valid from: Oct.22,2020

Valid until: Jul.16,2024

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Date of original issued: Sep.24,2020

President: _____

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China
<http://www.cqc.com.cn>

C 0414888



PRODUCT CERTIFICATE

CERTIFICATE NO.: CQC2019010305206643

NAME AND ADDRESS OF THE APPLICANT

J&A Apply Control Technology (Suzhou) CO., Ltd.
Block C, #03-04/02, No. 5 Xing Han Street Suzhou

NAME AND ADDRESS OF THE MANUFACTURER

MAFELEC
471 ROUTE DE LA CUISINIERE, CHIMILIN-FRANCE

NAME AND ADDRESS OF THE FACTORY

MAFELEC (V056397)
471 ROUTE DE LA CUISINIERE, CHIMILIN-FRANCE

PRODUCT NAME, MODEL AND SPECIFICATION

Change-over Switch

83580; Ui: 500V; Uimp: 6kV; Ith: 10A; AC-15: Ue/Ie: AC230V/8A; Aperture: Φ 22mm; Levels of Protection: IP20.

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T 14048.5-2017

TYPE OF CERTIFICATION SCHEMES

Type Testing of Product + Follow up Factory Inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC11-462142-2019 .

Valid from: Oct.22,2020

Valid until: Jul.16,2024

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Date of original issued: Sep.24,2020

President: _____

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China
<http://www.cqc.com.cn>

C 0414887



PRODUCT CERTIFICATE

CERTIFICATE NO.: CQC2019010305206642

NAME AND ADDRESS OF THE APPLICANT

J&A Apply Control Technology (Suzhou) CO., Ltd.
Block C, #03-04/02, No. 5 Xing Han Street Suzhou

NAME AND ADDRESS OF THE MANUFACTURER

MAFELEC
471 ROUTE DE LA CUISINIERE, CHIMILIN-FRANCE

NAME AND ADDRESS OF THE FACTORY

MAFELEC (V056397)
471 ROUTE DE LA CUISINIERE, CHIMILIN-FRANCE

PRODUCT NAME, MODEL AND SPECIFICATION

Change-over Switch
83581; Ui: 500V; Uimp: 6kV; Ith: 4A; DC-12: Ue/Ie: 72V/0.3A; Aperture: Φ 22mm; Levels of Protection:
_____ IP20.

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T 14048.5-2017

TYPE OF CERTIFICATION SCHEMES

Type Testing of Product + Follow up Factory Inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC11-462142-2019.

Valid from: Oct.26,2020 Valid until: Jul.16,2024

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Date of original issued: Sep.24,2020

President: _____

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China
<http://www.cqc.com.cn>

C 0416237



PRODUCT CERTIFICATE

CERTIFICATE NO.: CQC2011010302513510

NAME AND ADDRESS OF THE APPLICANT

J&A Apply Control Technology (Suzhou) CO., Ltd.
Block C, #03-04/02, No. 5 Xing Han Street Suzhou

NAME AND ADDRESS OF THE MANUFACTURER

MAFELEC
471 ROUTE DE LA CUISINIERE, CHIMILIN-FRANCE

NAME AND ADDRESS OF THE FACTORY

MAFELEC (V056397)
471 ROUTE DE LA CUISINIERE, CHIMILIN-FRANCE

PRODUCT NAME, MODEL AND SPECIFICATION

Rotary Switch

83582; Uimp: 2.5kV; Ui: 500V; Ith: 64A; Ue: AC380V; Ie: 64A; Icw: 1kA/0.3s; Icm: 1.41kA;
Utilization Category : AC-21B;

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T 14048.3-2017

TYPE OF CERTIFICATION SCHEMES

Type Testing of Product + Initial Factory Inspection + Follow up Factory Inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC11-462142-2019 .

Valid from: Oct.22,2020

Valid until: Oct.09,2021

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Date of original issued: Sep.24,2020

President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China
<http://www.cqc.com.cn>

C 0414886